



Simmco Vac
3908 Quiet Creek Dr.
Mississauga, ON, L5M 8B5
Phone: (416) 402-4222 or 24/7 (647) 281-2222
Fax: 905 997 5007
Email: service@simmcovac.com

POST-CLEANING CONSUMER CHECKLIST:

	YES	NO
GENERAL		
Did the contractor clean the entire heating and cooling system, including ductwork and all components?	<input type="checkbox"/>	<input type="checkbox"/>
HEATING		
Is the heat exchanger surface visibly clean?	<input type="checkbox"/>	<input type="checkbox"/>
COOLING		
Are both sides of the cooling coil visibly clean?	<input type="checkbox"/>	<input type="checkbox"/>
COMPONENTS		
If you point a flashlight into the cooling coil, does light shine through the other side? It should if the coil is clean.		
Is the coil fins straight and evenly spaced (as opposed to being bent over and smashed together)?	<input type="checkbox"/>	<input type="checkbox"/>
Is the coil drain pan completely clean and draining properly?	<input type="checkbox"/>	<input type="checkbox"/>
ACCESS DOORS AND COVERS		
Are newly installed access doors attached with more than just duct tape (i.e., screws, rivets, mastic, etc.)?	<input type="checkbox"/>	<input type="checkbox"/>
With the system running, there should be no air leakage through access doors or covers. Is this the case?	<input type="checkbox"/>	<input type="checkbox"/>
PLENUMS		
Is the return air plenum free of visible dust or debris?		
Do filters fit properly and are they the desired efficiency?		
Is the supply air plenum (directly downstream of the air handling unit) free of moisture stains and contaminants?	<input type="checkbox"/>	<input type="checkbox"/>
BLOWER		
Are the fan blades clean and free of oil and debris?	<input type="checkbox"/>	<input type="checkbox"/>
Is the fan compartment free of visible dust or debris?	<input type="checkbox"/>	<input type="checkbox"/>
METAL DUCTS		
Are interior ductwork surfaces free of visible debris? (Select several sites at random in both the return and supply sides of the system)	<input type="checkbox"/>	<input type="checkbox"/>
FIBERGLAS DUCT SURFACES		
Is the fiberglass material in good condition (i.e., free of tears and abrasions; well adhered to underlying materials)?	<input type="checkbox"/>	<input type="checkbox"/>
AIR VENTS		
Have you air vents been firmly reattached to the walls, floors, and / or ceilings?	<input type="checkbox"/>	<input type="checkbox"/>
Are the air vents visibly clean?	<input type="checkbox"/>	<input type="checkbox"/>
SYSTEM OPERATION		
Does the system function properly after cleaning?	<input type="checkbox"/>	<input type="checkbox"/>
Is the system operating free of any new or unusual noises?	<input type="checkbox"/>	<input type="checkbox"/>

If you answered "No" to any of the above questions, this may indicate a problem with the job. Speak to your contractor regarding these issues and ask him to make corrections to his work such that you can answer all questions "Yes."